

Test of Reasonableness Board (TORB)

As per the Equal Opportunities (Persons with Disability) Act I of 2000 Cap. 413 of the Laws of Malta

Our Ref: FebTORB_01

1st March 2019

Mr. Tonio Montebello
EkoCentre,
Triq il-Larmija,
Marsascala

PA/01519/18 – Xagħra, Gozo – Upgrading works to open rehabilitated landfill to public.

On Friday 22nd February 2019 the Test of Reasonableness Board (TORB) discussed a request for exemption received on the above indicated permit. Perit Eric Formosa, Perit Miriam Magri and Mr. Edric Micallef were present on behalf of the applicant.

Exemption was requested on the 'Il-Qortin ta' Ghajn Damma' landfill from being accessible for all.

CRPD objected on the following non-conforming elements:

External Areas:

- External paving material is not indicated on the drawing

Ramps:

- Ramps are not marked with Length, Width and Gradient
- Ramps are not marked with Spot Levels at the Beginning, Ending and on Landings
- Ramps are not provided with 1.5x1.5m landings at the Top and Bottom

Taking all arguments in consideration, the TORB concluded that it is **NOT REASONABLE** to exempt since insufficient information was provided on plans.



Rita Vella
Chairperson
Test of Reasonableness Board