

## Test of Reasonableness Board (TORB)

*As per the Equal Opportunities (Persons with Disability) Act I of 2000 Cap. 413 of the Laws of Malta*

---

13th September 2019

Our Ref: AugTORB\_02

Mr. George Pavia  
Aviation Security Malta (Ministry for Home Affairs and National Security)  
Malta International Airport  
Luqa LQA 4000

PA/04106/19 – Luqa – To sanction minor internal and external alteration to existing aviation security office block, and proposed minor internal alteration to basement level.

On Thursday 5th September 2019 the Test of Reasonableness Board (TORB) discussed a request for exemption received on the above indicated permit. Perit Krista Xuereb and Mr. Gino Pavia were present on behalf of applicant.

Exemption was requested on the existing office block from being accessible for all since it is not Aviation Security Malta's property but it is Malta International Airport (MIA)'s property.

CRPD objected on the following non-conforming elements:

- Main entrance door width should be indicated as per AADG2011.
- Spot levels should be provided where line could refer to change in level. Maximum threshold is 15mm.
- Turning circles should be provided where there is change in direction.
- Corridor width should be marked with the right dimension as per AADG2011.
- A declaration states that part of the reception height must be in accordance to AADG2011.
- No accessible to all at basement level (no lift).

Taking all arguments in consideration, the TORB concluded that it is **NOT REASONABLE** to exempt.



Rita Vella  
Chairperson  
Test of Reasonableness Board