

Test of Reasonableness Board (TORB)

As per the Equal Opportunities (Persons with Disability) Act I of 2000 Cap. 413 of the Laws of Malta

13th September 2019

Ref: AugTORB_03

PA/04209/18 – Qormi - Internal alterations including lower part of the existing floor, widening of existing internal door opening, a new kitchenette and a bathroom at Qormi Regional Library, St Ignatius College Primary Qormi St Sebastian, Triq Manwel Dimech, Qormi.

On Thursday 5th September 2019 the Test of Reasonableness Board (TORB) discussed a request for exemption received on the above indicated subject. Perit Karl Cutajar was present on behalf of the applicant.

CRPD's clearance for the above permit application was requested on the proposed development excluding the whole school since the library has its own separate entrance.

CRPD objected on the following non-conforming elements:

- Full development drawings should be provided to vet this application
- Levels should be marked where lines could refer as a step
- Ramp levels should be provided
- The accessible for all sanitary facilities should be marked on plans.
- The accessible for all sanitary facilities layout do not conform the AADG 2011.

In view that CRPD objection was mainly due to missing information on plans, applicants are requested to update and present drawings for the Qormi Regional Library with the required information for CRPD vetting.



Rita Vella
Chairperson
Test of Reasonableness Board