

## Test of Reasonableness Board (TORB)

*As per the Equal Opportunities (Persons with Disability) Act I of 2000 Cap. 413 of the Laws of Malta*

---

19th September 2019

Our Ref: 12SepTORB\_02

Mr. Darren Grima  
125, Flat 11  
Triq ix-Xatt  
Gżira GŻR 1027

PA/09533/18 – Swieqi – To sanction internal alterations at semi-basement level, and change of use from garages, and Class 4B to Class 4A. Demolition of ramp and installation of platform lift to cater for office.

On Thursday 12th September 2019 the Test of Reasonableness Board (TORB) discussed a request for exemption received on the above indicated permit. Perit Philip Farrugia and Mr. Darren Grima were present on behalf of applicant.

Full application was already granted by the Planning Authority and approved by CRPD. Minor amendment was submitted in July 2019 for a change to a smaller vertical platform lift than that approved and than what conforms to AADG 2011.

Reason for applying for a smaller platform lift is due to technical hardships found on site since the lift as approved by CRPD and as conforms to AADG 2011 has a pit deeper than the existent invert level.

Taking all arguments in consideration, the TORB concluded that it is **REASONABLE** accept the installation of the vertical platform lift proposed to Board and CRPD technical officers.



Rita Vella  
Chairperson  
Test of Reasonableness Board